

## **Forest View Acres Water District**

### **Operations Report – April, 2010**

.....Prepared by Erik Tameler, Southwest Water Co.

#### **Sampling:**

- The required sample was collected for Routine Coliform. Received results are inside the yellow folder in the Arapahoe treatment plant.

#### **Treatment Plants:**

##### **Arapahoe Water Plant:**

- Has been operating normally.
- Well level readings have been taken and are on file. I will compile recent results and forward at a later date.

##### **Transmission Line/Booster Station:**

- Normal Operation.

##### **Surface Water Plant:**

- Currently off-line pending secondary filter repairs. Repairs are tentatively scheduled for Friday, April 23.
- Repairs to the raw water line are scheduled for Monday, April 19<sup>th</sup>.

#### **Distribution system:**

- No breaks or leaks reported.

#### **Miscellaneous:**

- Replacement of the Surface Plant backflow device is complete.
- Specialty Resources Ltd. was contacted regarding pricing for the items requested at the March BOD meeting. A meeting was held on site to discuss the following items: pricing for developing an electrical schematic of the SWTP, pricing for a PLC for the SWTP, pricing for a SCADA system for the SWTP, and additionally, pricing for radio transmission of alarms at the SWTP to the autodialer at the AWTP.
- The creek is flowing heavily and last years channel reconstruction an dredging has been over run with fresh gravel. It appears the inlet channel is now full of gravel, covering the inlet structure.